



**District Level Water Analysis  
Laboratory U.P. Jal Nigam (Rural),  
Chandauli**  
Vyas Nagar Water Work Campus  
Village- Mahawalpur, Post-Dulahipur, Chandauli-  
232101



TC-17045

Water Analysis report

Report Number	CHA/Feb. 26/05	Date: 23/02/2026	Page No. 1
URL No.	TC17045260000045F		

Customer Details

Office Name and Addressed	Swargiya Ramvilash Singh Shikshan Sansthan, Rewsa, Pachpherwa, G T Road, Chandauli-232120
Ref. Letter No. & Date	SRVS/NOC/JN/2025-26/131: Date 20.02.2026

Basic Details of Sample

District	CHANDAULI	Block	CHANDAULI
Gram Panchayat / Nagar	REWSA	Village / NPP	REWSA
Habitation	PACHPHERWA	Location	School Campus
Water Source	Submersible	Sample Code	CHA/Feb. 26/05
Quantity of Sample	1000 mL (Normal)	Date of Sample Collection	20/02/2026
Receiving Date	20/02/2026	Sample Collector	Mr. Suresh
Sample Depositor	Mr. Suresh	Sampling Method Used	NA
Latitude (N)	-	Longitude (E)	-
Analysis Start Date	21/02/2026	Analysis Completion Date	23/02/2026

Environmental Condition

Temperature	25±3 °C	Humidity	50±15%
-------------	---------	----------	--------

Technical Data of Analysis

S. No.	Analysis Parameter	Units	Observed Value	Specified Value as per BIS 10500:2012 (Second Revision)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1.	Taste	-	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 8): 2023
2.	Odour	-	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 5): 2018
3.	Colour	HU	8.00	5	15	IS 3025 (Part 4): 2021 (Platinum Cobalt Visual Comparison Method)
4.	Turbidity	(NTU)	0.89	1.00	5.00	IS 3025 (Part 10): 2023 (Nephelometric Method)
5.	pH	-	7.46	6.5-8.5	No Relaxation	IS 3025 (Part 11): 2022 (Electrode Method)
6.	TDS	(mg/L)	232.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric Method)
7.	Chloride	(mg/L)	24.00	250	1000	IS 3025 (Part 32): 1988 (Argentometric Method)
8.	Fluoride	(mg/L)	0.24	1.0	1.5	APHA 24 th Edition-4500- F Method C (Electrode Method), 2005
9.	Sulphate	(mg/L)	8.69	200	400	APHA 24 th Edition-4500- SO4 Method E (Turbidimetric Method), 2023
10.	Nitrate	(mg/L)	0.38	45	No Relaxation	APHA 24 th Edition-4500- NO3 Method B (UV Screening Method), 2023
11.	Iron	(mg/L)	0.27	1.00	No Relaxation	APHA 24 th Edition-3500- Fe Method B (Phenanthroline Method), 2023
12.	Total Hardness	(mg/L)	136.00	200	600	IS 3025 (Part 21): 2009 (EDTA Method)
13.	Total Alkalinity	(mg/L)	148.00	200	600	IS 3025 (Part 23): 2023 (Indicator Method)
14.	Total Arsenic	(mg/L)	00.00	0.01	No Relaxation	APHA 24 th Edition-3500 Method B (SDDC Method), 2023
15.	Calcium	(mg/L)	17.60	75	200	IS 3025 (Part 40): 2024 (EDTA Method)
16.	Magnesium	(mg/L)	22.08	30	100	IS 3025 (Part 46): 2024 (Volumetric Method)

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
  2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head Laboratory.
  3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.
  5. Parameters above permissible limit are written in Bold.
  6. Sample is not collected by lab.

**Manish Kumar**

Manish Kumar  
Report prepared by

**Shaharaj Ali**  
Shaharaj Ali  
Review by



**Dheeraj Tripathi**  
(Dheeraj Kumar Tripathi)  
Authorized Signatory



**District Level Water Analysis Laboratory U.P.  
Jal Nigam (Rural), Chandauli**

**Water Analysis report**

<b>Report Number</b>	<b>CHA/Feb. 26/05</b>	<b>Date: 23/02/2026</b>	<b>Page No. 2</b>
<b>URL No.</b>	-		

**Customer Details**

<b>Office Name and Addressed</b>	Swargiya Ramvilash Singh Shikshan Sansthan; Rewsa, Pachpherwa, G T Road, Chandauli-232120
<b>Ref. Letter No. &amp; Date</b>	SRVS/NOC/JN/2025-26/131: Date 20.02.2026

**Basic Details of Sample**

<b>District</b>	CHANDAULI	<b>Block</b>	CHANDAULI
<b>Gram Panchayat / Nagar</b>	REWSA	<b>Village / NPP</b>	REWSA
<b>Habitation</b>	PACHPHERWA	<b>Location</b>	School Campus
<b>Water Source</b>	Submersible	<b>Sample Code</b>	CHA/Feb. 26/05
<b>Quantity of Sample</b>	1000 mL (Normal)	<b>Date of Sample Collection</b>	20/02/2026
<b>Receiving Date</b>	20/02/2026	<b>Sample Collector</b>	Mr. Suresh
<b>Sample Depositor</b>	Mr. Suresh	<b>Sampling Method Used</b>	NA
<b>Analysis Start Date</b>	21/02/2026	<b>Analysis Completion Date</b>	23/02/2026
<b>Latitude (N)</b>	-	<b>Longitude (E)</b>	-

**Environmental Condition**

<b>Temperature</b>	25±3 °C	<b>Humidity</b>	50±15%
--------------------	---------	-----------------	--------

**Technical Data of Analysis**

S. No.	Analysis Parameter	Units	Observed Value	Specified Value as per BIS 10500:2012 (Second Revision)		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1.	Total coliform	CFU	0.00	Shall not be detectable in any 100ml sample	No Relaxation	APHA 24 <sup>th</sup> Edition: 2023
2.	E.coli	CFU	0.00	Shall not be detectable in any 100ml sample	No Relaxation	APHA 24 <sup>th</sup> Edition: 2023

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
  2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
  3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  4. Sample will be stored up to 7 days from the date of issue of test reports unless otherwise specified.
  5. Parameters above permissible limit are written in Bold.
  6. Sample is not collected by lab.

Prakhar Singh  
Prepared By

*Prakhar Singh*

(Dheeraj Kumar Tripathi)  
Approved By

*Dheeraj Tripathi*



\*\*\*\*\*END OF REPORT\*\*\*\*\*



कार्यालय अधिशासी अभियन्ता, खण्ड कार्यालय,  
उ० प्र० जल निगम (ग्रामीण), चन्दौली

पत्रांक

1213

/

जल परीक्षण

/

16

दिनांक 28-02-26

सेवा में,

प्राधानाचार्या,

स्व० राम विलास सिंह शिक्षण संस्थान,

रेवसा, पचफेड़वा, जी०टी० रोड, चन्दौली।

विषय- विद्यालय परिसर हेतु जल परीक्षण प्रमाण पत्र जारी करने के सम्बन्ध में।

महोदया,

अवगत कराना है कि आपके द्वारा स्व० रामविलास सिंह शिक्षण संस्थान, रेवसा, पचफेड़वा, जी०टी० रोड, चन्दौली उपलब्ध कराये गये एक नग जल नमूना का भौतिक, रासायनिक एवं जीवाणु परीक्षण के उपरान्त जल परीक्षण रिपोर्ट आपके अग्रिम कार्यवाही हेतु प्रेषित है।

संलग्नक:- जल परीक्षण रिपोर्ट

भवदीय,

(अमित कुमार राजपूत)  
अधिशासी अभियन्ता

कार्यालय-मुख्य चिकित्सा अधिकारी, चन्दौली।

पत्रांक: मु0चि0अ0/विद्यालय/2026-27/415

दिनांक: 02.05.2026


प्रमाण-पत्र

प्रमाणित किया जाता है कि स्व0 राम विलास सिंह शिक्षण संस्थान ग्राम-रेवसा (पचफेड़वा जी0टी0 रोड) चन्दौली के पत्रांक SRVS/NOC/PS/2025-26/132 दिनांक 23.02.2026 के द्वारा किये गये अनुरोध पर स्थलीय निरीक्षण हेतु डा0 गुलाब वर्मा, अपर मुख्य चिकित्सा अधिकारी, चन्दौली को भेजा गया।

जांच रिपोर्ट:-

1. साफ सफाई व्यवस्था -- सन्तोषजनक
  2. स्वच्छ पेयजल उपलब्धता स्थिति -- सन्तोषजनक
  3. पर्यावरण से आच्छादन की स्थिति व हरियाली -- सन्तोषजनक
- समेकित रूप से पठन पाठन हेतु उपरोक्त वातावरण एवं व्यवस्था।

अतः अनापत्ति प्रमाण-पत्र निर्गत।

  
मुख्य चिकित्सा अधिकारी  
चन्दौली।  
पदावी